



THIS DRAWING IS THE PROPERTY OF PRIMARY FLUID SYSTEMS INC. FROM WHICH A WRITTEN CONSENT FOR APPROVAL SHALL BE REQUIRED PRIOR TO COPYING.

| | NO. | NAME | DESCRIPTION |
|-------------|-----|---|--------------------------|
| | 1 | MAX ALLOWABLE OPERATING TEMPERATURE | 140°F (60°C) |
| | 2 | MAX ALLOWABLE OPERATING PRESSURE | 15 PSIG |
| CONNECTIONS | 3 | BOTTOM PORT CONNECTION | 2" |
| | 4 | TOP PORT CONNECTION | 2" |
| | 5 | TYPE | NPT |
| MATERIALS | 6 | CYLINDER | CLEAR PVC |
| | 7 | END CAP | PVC |
| | 8 | GLUE | CPVC, CHEMICAL RESISTANT |
| INPUT DATA | 9 | VOLUME SIZE | 20000 ML / 320 GPH |
| SCALE | 10 | BI DIRECTIONAL GRADUATIONS | 200 ML / 2 GPH DIVISIONS |
| COMMENTS | 11 | ALL CYLINDERS ARE RATED FOR LIQUID SERVICE ONLY | √ |
| | 12 | CYLINDERS ARE NOT PRESSURE VESSELS | √ |
| | | NSF 61 APPROVED | |

ACCUDRAW®
PV#2 PVC CALIBRATION CYLINDER



| REV | DESCRIPTION | DATE | NAME |
|-----|-------------|------|------|
| 0 | NEW DRAWING | -- | -- |

| | | | | |
|---|--|----------------------|-----------------------|---|
| PRIMARY FLUID SYSTEMS INC. 1050 COOKE BLVD, BURLINGTON, ONTARIO L7T 4A8 | | PROJECT: PV | SHT: 1 OF 1 | DRAWN BY: NG |
| TITLE: 20000 ML CALIBRATION CYLINDER WITH 2" NPT CONNECTION | | DATE DRAWN: 5/9/2016 | SCALE: 1:4 | UNITS: INCH [mm] |
| DWG NO: PV#2-20000_R0 | | MATERIAL: SEE CHART | DWG NAME: PV CYLINDER | REV# 0 |
| DWG TYPE: PLANAR VIEW | | APPROVED BY: | CHECKED BY: | DIMENSIONAL TOLERANCE 0.X = ± 0.25" 0.XX = ± 0.25" 0.XXX = ± 0.25" |