

HOW TO ORDER

PFS CORPORATION STOPS

Corporation Stops Standard Material of Construction

Body Material (see below for options)

CCS = 1/2" connection on quill feed, 3/4" mnpt connection to system with Viton seal

CCSE = 1/2" connection on quill feed, 3/4" mnpt connection to system with EPDM seal

316 Stainless Steel Spring

Ceramic Ball

1/8" Discharge Orifice

Example: CCS-58-CPVC-HI

CCS = pipe connection with Viton seal

1/2" npt

4 5/8" insertion

CPVC (Corzan)

Hastelloy C spring & ball

NOTE: CRN is available on certain Corporation Stops. Please contact factory for price and availability.

OTHER MATERIAL OF CONSTRUCTION AND BUBBLE TIGHT/RESILIENT SEAT CHECK VALVE AVAILABLE UPON REQUEST

e.g. Part # CCS-58-CPVC-HI-25

CCS - 58 - CPVC - HI - 25

CORPORATION STOPS

CCS = 3/4" mnpt connection to system
with Viton seal

CCSE = 3/4" mnpt connection to system
with EPDM seal

QUILL CONNECTION

5 = 1/2" NPT

5B = 1/2" BSPT

5F = 1/2" Flg'd

7 = 3/4" NPT

7B = 3/4" BSPT

7F = 3/4" Flg'd

Other connection sizes
available upon request

INSERTION LENGTH

6 = 2 5/8"

8 = 4 5/8"

Longer insertions
available upon request

The standard discharge orifice is 1/8"
-25 = Optional 1/4" discharge orifice for
higher capacity flow
Hastelloy units only available with 1/4"

OPTIONAL: (Suffix) SPRING AND BALL MATERIALS

H = Hastelloy "C" Spring

I = Hastelloy "C" Ball

TS = Titanium Beta "C" Spring

TB = Titanium Grade 2 Ball

K = PVDF Ball Material

T = PTFE Ball Material

BODY MATERIAL

PVC = Polyvinylchloride

PP = Polypropylene

PVDF = Polyvinylidene fluoride

316S/S = 316 Stainless Steel

HAST = Hastelloy "C" 276

CPVC = CPVC Corzan